

**Morrison Bros. Co.**  
325 East 24<sup>th</sup> Street  
P.O. Box 238  
Dubuque, IA 52004-0238

Tel: 800-553-4840  
Tel: 563-583-5701  
Fax: 563-583-5028  
*E-mail: [custserv@morbros.com](mailto:custserv@morbros.com)*

---

## **MAINTENANCE PROCEDURES**

### **Fig. 244 Series Emergency Vents**

Monthly inspection, and immediate inspection during freezing conditions, by someone familiar with the proper operation of storage tank vents, is required to insure venting devices are functioning properly before filling or unloading a tank. The cover of the Fig. 244 Series Emergency Vents must move up and down freely for the vent to work properly. There should be no binding or sticking when lifting the cover, or lowering it back down onto the body. Maintenance should also include an inspection of the o-ring or brass seat ring to insure they are in good working condition.